

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 25-Mar-2003	4. REQUISITION/PURCHASE REQ. NO. W807PM-2352-6957		5. PROJECT NO.(If applicable)
6. ISSUED BY CONSTRUCTION & A/E BRANCH 4155 CLAY STREET VICKSBURG MS 39183-3435	CODE DACW38	7. ADMINISTERED BY (If other than item 6) See Item 6		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. DACW38-03-B-0007	
		X	9B. DATED (SEE ITEM 11) 18-Feb-2003	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.				
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Reference Invitation for Bid No. DACW38-03-B-0007, dated 18 Feb 03 for FC/MR&T, Yazoo River Basin, Panola County, Mississippi, Demonstration Erosion Control (DEC), Bank Stabilization, Long Creek Watershed, Courtland City Creek (BS-02-01), scheduled to open at 1400 hours on 20 March 2003, is amended as follows: CONTINUED ON PAGE 2				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)	16C. DATE SIGNED 25-Mar-2003	

BID OPENING DATE

A new bid opening date and time of 8 April 2003 at 1400 hours is hereby established.

I. TECHNICAL SPECIFICATIONS :

1. Section 02541, paragraph 1.5 MEASUREMENT AND PAYEMENT, replace subparagraph 1.5.1.1 Measurement for Gabions with revised subparagraph 1.5.1.1 Measurement for Gabions.

2. Delete Section 01312 QUALITY CONTROL SYSTEM (QCS).

II. DRAWINGS:

Make pen and ink changes to the following:

Sheet 23, Cross Section 21+21, change the RIPRAP - 1' THICKNESS, to read RIPRAP - 16" THICKNESS.

Page revised by this amendment has asterisks in the margin notating changes and the notation "Revised by Amendment No. 0002" at the bottom of the page.

Encl: Section 02541, Page 3

SD-14 Samples

Stone Fill; GA.

Samples of stone fill material submitted for approval prior to delivery.

1.4 DESCRIPTION

Gabion units shall consist of compartmented rectangular basket containers filled with stone. Twisted or welded wire mesh shall be used. Baskets shall be fabricated from extruded or extruded and bonded polyvinyl chloride (PVC) galvanized steel wire formed into a nonraveling mesh.

1.5 MEASUREMENT AND PAYMENT

1.5.1 Gabions

*1.5.1.1 Measurement for Gabions

Gabions in place, meeting the requirements of these specifications, and acceptably placed within the limits indicated on the drawings or otherwise established in the field by the Contracting Officer, will be measured to the nearest cubic yard. Tie wires will not be measured for payment nor paid for separately and all costs incidental thereto shall be included in the contract unit price for "Gabions". Graded stone placed in the gabions will not be measured for payment nor paid for separately and all cost incidental thereto shall be included in the contract unit price for "Gabions".

1.5.1.2 Payment for Gabions

Payment for gabions accepted in the work and measured as specified under measurement above, will be made at the contract unit price for "Gabions", which price shall include all cost of furnishing, hauling, assembling, and placing the wire baskets, placing the stone in the wire baskets, and all other materials, labor, equipment, tools, supplies, and incidental cost in connection with completing this item of work.

PART 2 PRODUCTS

2.1 MATERIALS

2.1.1 Gabions

2.1.1.1 PVC-Coated Steel Wire Mesh Gabions

Gabion basket units shall be of nonraveling construction and fabricated from a double twisted hexagonal mesh or welded wire mesh of hot dipped galvanized steel wire. The galvanized wire shall be coated with a nominal thickness of 0.0216 inches and a minimum thickness of 0.015 inches of extruded or extruded and bonded PVC or fusion-bonded PVC. The steel core wire used shall be galvanized and PVC-coated. Mesh openings shall be hexagonal in shape and uniform in size measuring approximately 3 1/4 inches by 4 1/2 inches for twisted wire mesh. If welded, the welded wire mesh panels may be trimmed in such a way that the severed ends of the wires are located a minimum of 1/4 to 1/2 inch from the nearest weld. All trimmed wires shall be folded back so that they do not protrude from the assembled gabion. The core wire of all gabion diaphragm and frame components shall