

2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 7-Jan-2002	4. REQUISITION/PURCHASE REQ. NO. W81EWF-1284-8281	5. PROJECT NO. <i>(If applicable)</i>
6. ISSUED BY VBURG CONSOL CONTRACTING OFC 4155 CLAY ST VICKSBURG, MS 39183-3435	CODE DACW42	7. ADMINISTERED BY <i>(If other than Item 6)</i> See Item 6	

8. NAME AND ADDRESS OF CONTRACTOR <i>(No., street, county, State and ZIP Code)</i>	(√)	9A. AMENDMENT OF SOLICITATION NO. DACW42-02-B-0001
	X	9B. DATED <i>(SEE ITEM 11)</i> 12-Dec-2001
		10A. MODIFICATION OF CONTRACTS/ORDER NO.
		10B. DATED <i>(SEE ITEM 13)</i>
CODE	FACILITY CODE	

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers is extended, is not extended.

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning 1 copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA *(If required)*
96X3112, FC/MR&T

13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.

(√)	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: <i>(Specify authority)</i> THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES <i>(such as changes in paying office, appropriation date, etc.)</i> SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER <i>(Specify type of modification and authority)</i>

E. IMPORTANT: Contractor is not, is required to sign this document and return _____ copies to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION *(Organized by UCF section headings, including solicitation/contract subject matter where feasible.)*
Reference Invitation for Bids No. DACW42-02-B-0001 for Replacement of Chiller and Cooling Tower for Building 3396, at the U. S. Army Engineer and Research Center, Waterways Experiment Station, Vicksburg, Mississippi, scheduled to open 1400 Hrs, 15 Jan 2002, is amended as follows:

TECHINCAL SPECIFICATIONS

SECTION 15650, CENTRAL REFRIGERATED AIR CONDITIONING SYSTEM: Paragraph 2.4.1 is amended by the inclusion of additional information added by Page 11-A.

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.

15A. NAME AND TITLE OF SIGNER <i>(Type or print)</i>	16A. NAME AND TITLE OF CONTRACTING OFFICER <i>(Type or print)</i>		
15B. CONTRACTOR/OFFEROR _____ <i>(Signature of person authorized to sign)</i>	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY _____ <i>(Signature of Contracting Officer)</i>	16C. DATE SIGNED

* The chiller and cooling tower selection shall be based on the following data:

GPM Chilled Water - 767

Cooler PD - 24 feet

GPM Condenser Bundle – 934

Condenser Bundle PD – 18 feet

GPM Heating Bundle – 181

Heating Bundle PD – 8 feet

Entering Chilled Water – 52 degrees F

Leaving Chilled Water – 42 degrees F

Entering Condenser Water – 85 degrees F

Leaving Condenser Water – 95 degrees F

Heat Capacity @95 degrees F leaving Condenser Water – 648 MBH @ 45 tons *