

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE J	PAGE OF PAGES 1   3
2. AMENDMENT/MODIFICATION NO. 0001	3. EFFECTIVE DATE 27-Aug-2004	4. REQUISITION/PURCHASE REQ. NO. W807PM-4149-2435	5. PROJECT NO.(If applicable)	
6. ISSUED BY VBURG CONSOL CONTRACTING OFC 4155 CLAY ST VICKSBURG MS 39183-3435	CODE W912EE	7. ADMINISTERED BY (If other than item 6) <b>See Item 6</b>		
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)		X	9A. AMENDMENT OF SOLICITATION NO. W912EE-04-T-0055	
		X	9B. DATED (SEE ITEM 11) 16-Jul-2004	
			10A. MOD. OF CONTRACT/ORDER NO.	
			10B. DATED (SEE ITEM 13)	
CODE	FACILITY CODE			
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>				
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended.				
Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.				
12. ACCOUNTING AND APPROPRIATION DATA (If required)				
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>				
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.				
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).				
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:				
D. OTHER (Specify type of modification and authority)				
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.				
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) Reference Request For Quotations (RFQ) No. W912EE-004-T-0055 to furnish and deliver Electrical Supplies. Subject RFQ is amended as follows:  <div style="text-align: center;">See Page 2 for Amendment Instructions</div>				
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.				
15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)		
		TEL: _____ EMAIL: _____		
15B. CONTRACTOR/OFFEROR	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA	16C. DATE SIGNED	
_____ (Signature of person authorized to sign)		BY _____ (Signature of Contracting Officer)	27-Aug-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

**SUMMARY OF CHANGES**

SECTION SF 1449 - CONTINUATION SHEET

SOLICITATION/CONTRACT FORM

**Standard Form 1449, Block 8.** Offer Due Date/local time, the required response date/time has changed from 27-Jul-2004 04:45 PM to 08-Sep-2004 04:45 PM. Please make pen and ink changes where applicable.

**Page 5a of 28 has been added. The Specification for this requirement has been added.**

Pages revised by this amendment have asterisks in the margin before and after changes to previous issue.

Encl:

Page 5a of 28

(End of Summary of Changes)

**SPECIFICATIONS**

167.5 KVA ABB type, or equal;  
Tamper proof outdoor pad-mount w\2 door (not mini-pad). One door high voltage compartment and one door low voltage compartment with door stops. Low voltage door must open before high voltage door will open. Compartment weather cover, hinged to lift and secure into place w/supporting arm. Transformer Rated 1 phase, 60 Hz, 65 C degrees rise, OSIC, class OA, mineral oil filled w\NO-PCB's and so labeled; including Steel high\low voltage compartment barrier; Impedance not less than 2%; HV 13200GRDY/7620 manually operated de-energized tap changer with primary winding switching, with 2 above and 2 below neutral Low voltage secondary; 120/240 1 phase  
Dead front-loop feed w/wells with one single feed and two feed thru wells switch able w/ parking stand externally clamp type HV bushing wells for load break or non LB inserts  
4 position load break oil rotary switch (LBOR switch-loop design)  
Bayonet fuses  
External Tap changer  
1 each-10 KV high voltage lightning arrestor, type MOV dead front complete with 15 kv plug-in elbow  
All windings & internal connections to be copper; constructed to ANSI C57.12.00  
3-low voltage spade terminals, right of center-line, copper spades w\ studs and contact nuts with rotating spades - 4 hole spade connectors with 4 each mechanical 4\0-600 MCM/CU lugs per low voltage spade. With removable neutral ground strap  
Standard ANSI accessories  
Conform to all applicable ANSI & IEEE standards; C57.12.00-12.91\  
Tamper-proof removable bolted cabinet with three point latching lift off doors w/stainless steel hinges and open bottom for conduit, cable entrance  
Transformer bottom base and complete front compartment to be 304L stainless steel.  
Low voltage compartment door provide locking door bolt w\ bolt/padlock handle operating cam assy'm that is 3 point door latching mechanism;  
Low voltage compartment door overlapping high voltage compartment door to prevent access to high voltage compartment until low voltage compartment door opened  
Provide R.E.A. type 1/2" captive penta head compartment door locking bolt  
One each DANGER HIGH VOLTAGE warning sign mounted on outside of HV compartment door and 3 ea. DANGER HIGH VOLTAGE warning decals mounted on sides of compartments and back of tank  
Door stops on high voltage and low voltage compartment doors to prevent accidental closing while open position;  
Transformer paint as per ANSI C57. 12.28 painted bell green  
Transformer data sheet; clearance for bushing on high voltage & low voltage, location handholds, location and id of all accessories, size and location conduit/cable entrances for buyers connections, ground pad locations, ect.; Provide an instruction, operating and maintenance manual covering all equipment furnished.